

Fire protection

86. This is dealt with in Chapter 11, paragraphs 180–182.

Ramps

87. The gradient should preferably be constant and not broken by steps.

88. The maximum gradient acceptable will depend on the particular ramp's length, purpose and usage but a ramp subject to heavy crowd flow should preferably not exceed a gradient of 1 in 10.